

Date: 2025-05-27

NeoVolta Inc.
12195 Dearborn Place
Poway CA 92064
USA

Ref: CU US + Canada Certificate

Type of Equipment : Low Voltage Hybrid ESS
Certificate No. : CU 72501921 0001
Report No. : CN253M5E 002
Engineer/Contact : Mino Yu
Standards : ANSI/CAN/UL 9540:2023

Dear Madame or Sir,

The above referenced technical equipment has been tested and was found to be in compliance with the listed test requirement(s). Enclosed, please find the TUV Rheinland approval document No. CU 72501921 0001.

It authorizes you to label the listed product(s) with the TUV Rheinland Mark identified in the approval document. For compliance, the Test Mark must be on the approved unit.

Your product is subject to regular factory follow-up inspections as well as annual certificate and factory registration fees.

In using the TUV Rheinland Mark you are obligated to comply with the TUV Rheinland of North America Service Agreement.

If we can be of any further assistance to you, please do not hesitate to contact us.

With kind regards,

Certification Body



Weichun Li

Enclosure

Certificate

Certificate no.

CU 72501921 0001

License Holder:

NeoVolta Inc.
12195 Dearborn Place
Poway CA 92064
USA

Manufacturing Plant:

CN253M5E

Report Number:

CN253M5E 002

Client Reference:

Michael Mendik

Certification acc. to:

ANSI/CAN/UL 9540:2023

Product Information

Certified Product:

Low Voltage Hybrid ESS

Model Designation:

NV PLUS-FX-YK
(X=1, 2, 3, 4, 5;
which means the number of batteries in parallel,
Y=7.6, 15.2, 22.8, 30.4;
which means the power of PCS in parallel)

Technical Data:

Nominal voltage ac : 120/240V, 208V
Rated Energy (kWh) : 10.24*X (X=1, 2, 3, 4, 5)
Other Data : See Appendix(Constr. Data Form)

Remarks:

Appendix:

1, 1-13

Date of issue:

2025-05-27
(yr/mo/day)

